


Cover identification:
STREET LIGHTING
HIGH VOLTAGE




PULL BOX NO.	TYPE	DIMENSIONS			
		Outside		Cover	
		A	B	C	D
5	PCC	635 (25")	380 (15")	550 (21 3/4")	300 (11 3/4")
6	PCC	865 (34")	560 (22")	755 (29 3/4")	450 (17 3/4")

NOTE:


Pull boxes shall be non-boltdown
type unless noted.

PULL BOX DETAILS

PCC apron, 75 mm (3") thick around
pull box. Delete apron if pull box is
constructed within a sidewalk



TYPICAL PULL BOX INSTALLATION



TYPICAL CONDUIT INTERCEPT

NOTE:

Size of coupler and new conduit shall be same size as existing conduit

Dimensions are in millimeters, except as noted

REVISIONS		CITY OF LONG BEACH, CALIFORNIA DEPARTMENT OF PUBLIC WORKS	STANDARD PLAN NO.
NO.	DATE		
1	01/21/98	PULL BOX & CONDUIT DETAILS	METRIC 708
2	12/23/02		
3		APPROVED BY: <i>Mark Chittell</i>	SHEET
4		CITY ENGINEER R.E. No. 4029	1 OF 1
		DATE: 1/10/03	
		EX. DATE: 03/31/03	